

June 16, 2026

2025-CRW-1028

To: All Bidders of Record

Re: Addendum No. Three (3)
Electric Charging Station
West Virginia International Yeager Airport (CRW)

Dear Bidders:

This Addendum is hereby made part of the Contract Documents for the above reference project. All other requirements of the original documents shall remain in effect in their respective order.

Bid Opening – The Bid Opening will take place on **June 23 (6/23) at 2:30pm. (REVISED)**

Clarification –

Addendum No. 1, Question/Answer No. 4 stated that the CT Cabinet would be provided by AEP. However, Addendum No. 2, Attachment No. 1 included the AEP CT Cabinet detail, which states that the **Contractor shall provide the CT Cabinet**. For clarification, **the Contractor is responsible for furnishing and installing the CT Cabinet in accordance with the AEP detail included in Addendum No. 2, Attachment No. 1.**

The Contractor shall include all costs associated with the CT Cabinet in the lump sum price for **Electrical Work (Bid Item No. 3)**.

LIST OF ATTACHMENTS

1. None

– END OF ADDENDUM NO. THREE (3) –

If you should have any questions regarding this matter, please do not hesitate to contact our office.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Rebecca McDonald', with a long horizontal flourish extending to the right.

Rebecca McDonald, PE
Project Engineer

RM

Cc: West Virginia International Yeager Airport (CRW)